



**JUGOINSPEKT BEOGRAD AD**  
**Direkcija CA – CERTIFIKACIONO TELO**  
JUGOINSPEKT BEOGRAD AD, Direkcija CA, Čika Ljubina 8/V,  
tel. 011 3032-145, fax. 011 2626-349  
web:www.jugoinspekt.com E-mail – dirca@sezampro.rs.

H001

**POTVRDA O USAGLAŠENOSTI**  
**CONFIRMATION OF CONFORMITY**

Broj: **P1-910/19**

No.

Opis proizvoda: <i>Product description:</i>	<b>PRIKLJUCNICA SA USB PUNJACEM</b>
Tipaska oznaka, model: <i>Type designation, model:</i>	<b>UP+2, PP5/2+2, PP5/3+2, PP5/5+2; 2/310-0113, 2/310-0114, 2/310-0115, 2/310-0116.</b>
Podnosilac zahteva: <i>Applicant:</i>	<b>TEHNOELEKTRO TIM D.O.O., Ul. Lele Popovic bb., 18220 Aleksinac.</b>
Proizvođač: <i>Manufacturer:</i>	<b>TEHNOELEKTRO TIM - SRBIJA</b>
Vrednovana dokumentacija proizvođača <i>Evaluated Documentation of producer</i>	
Ispitni izveštaj, broj: <i>Test report, number:</i>	<b>015/19</b>
Izdat od: <i>Issued by:</i>	<b>RFS Laboratorija-Institut Bezbednosti, Beograd</b>
Na osnovu gore navedene dokumentacije utvrđeno je da gore navedeni proizvod zadovoljava zahteve Pravilnika elektromagnetskoj komaptibilnosti-EMC(Sl. glasnik RS, 25/2016). On the basis of the above mentioned documentation is found that above mentioned product fulfils the requirements of the Regulation of electromagnetic compatibility-EMC(Sl. glasnik RS, 25/2016)	
Nastale promene u specifikaciji, tipu/modelu, komponentama, električnim karakteristikama proizvoda koji utiču na usaglašenost sa navedenim Pravilnikom moraju se prijaviti "Jugoinspekt"-u a.d. Beograd. Any changes occur in the specification type/model, components or the design, electrical construction which may influence on EMC of the product shall be forward to certification body.	

Mesto i datum izdavanja:  
*Place and date:*

Beograd, 18.11.2019.

Važi do:  
*Valid Unt:*

18.11.2024.

Pečat i Potpis ovlašćenog lica:  
*Seal and Sign:*

Dipl.inž.šum. Ilija Smiljanić





# TEHNOELEKTRO-TIM D.O.O.

Lele Popović b.b., 18220 Aleksinac, Srbija  
Tel/Fax +381 18 800-252, 800-253, 800-392, 800-393.


[info@tehoelektro.rs](mailto:info@tehoelektro.rs) [www.tehoelektro.rs](http://www.tehoelektro.rs)

RB/MB:20906227; PD:2790; PIB:107964407

Komercijalna banka: 205-187000-39; Čačanska banka: 155-23572-07

## DEKLARACIJA O USAGLAŠENOSTI

**No.005/19**

<b>Adresa proizvođača</b>	TEHNOELEKTRO TIM Lele Popovic bb, 18220 Aleksinac, Srbija
<b>Proizvod</b>	Priključnica sa USB punjačem
<b>Robna marka proizvoda</b>	
<b>Br. artikla / Tip</b>	2/310-0113/ UP+2, 2/310-0114/PP5/2+2, 2/310-0115/PP5/3+2, 2/310-0116 PP5/5+2
<b>Osnovne karakteristike proizvoda</b>	Napon / struja priključnice 250V/16A Napon na izlazu punjača 5V Struja punjača 2A
<b>Propisi / Standardi</b>	SRPS EN 55014-1:2010/A1:2010 SRPS EN 55014-1:2012/A2:2012 Ispitni izveštaj 015/19
<b>Napomena</b>	Pravilnik o elektromagnetskoj kompatibilnosti EMC SI glasnik RS 25/2016

Aleksinac, 18.11. 2019.

*Bojan Milutinović*

Bojan Milutinovic, M.Sc..E.  
IT & QMS manager  
Sluzba kontrole kvaliteta



V001 19



H001

# JUGOINSPEKT BEOGRAD A.D.

## PJ Direkcija CA – SERTIFIKACIONO TELO

JUGOINSPEKT BEOGRAD A.D., PJ Direkcija CA, Čika Ljubina 8/V,  
tel. 011 3032-145, fax. 011 2626-349  
web: [www.jugoinspekt.com](http://www.jugoinspekt.com), E-mail – [direkcijaca@jugoinspekt.com](mailto:direkcijaca@jugoinspekt.com)  
[dirca@sezampro.rs](mailto:dirca@sezampro.rs).

### POTVRDA O USAGLAŠENOSTI CONFIRMATION OF CONFORMITY

Broj: P2-084/20  
No.

Opis proizvoda: <i>Product description:</i>	PRIKLJUCNICA SA USB PUNJEČEM
Tipska oznaka, model: <i>Type designation, model:</i>	UP+2; PP5/2+2; PP5/3+2; PP5/5+2; 2/310-0113; 2/310-0114; 2/310-0115; 2/310-0116.
Podnosilac zahteva: <i>Applicant:</i>	TehnoelektroTim D.O.O., Lele Popović bb, 18220 ALEKSINAC
Proizvođač: <i>Manufacturer:</i>	TehnoelektroTim D.O.O., - Srbija
Vrednovana dokumentacija proizvođača <i>Evaluated Documentation of producer</i>	
Ispitni izveštaj, broj: <i>Test report, number:</i>	TMP 03
Izdat od: <i>Issued by:</i>	Tehnoelektro - Srbija
<p>Na osnovu gore navedene dokumentacije i kompetencije kadrova (dugogodišnjem iskustvu) i renomiraranosti i dokazanog kvaliteta proizvođača utvrđeno je da gore navedeni proizvod zadovoljava zahteve Pravilnika o električnoj opremi namenjenoj za upotrebu u okviru određenih granica napona (Sl. glasnik RS, 25/2016). On the basis of the above mentioned documentation and competence of staff (many years of experience), and renowned and proven quality of the manufacturer is found that above mentioned product fulfils the requirements of the Regulation on electronic equipment intended to be used within specified limits of voltage (Official Gazette RS, 25/2016).</p> <p>Nastale promene u specifikaciji, tipu/modelu, komponentama, električnim karakteristikama proizvoda koji utiču na usaglašenost sa navedenim Pravilnikom moraju se prijaviti "Jugoinspekt"-u a.d. Beograd. The changes in the specification, type / model, components, electrical characteristics of the products that affect the compliance with the aforementioned Regulation must be reported to "Jugoinspekt" in a.d. Belgrade.</p>	

Mesto i datum izdavanja:  
*Place and date:*

Beograd, 26.02.2020.

Važi do:  
*Valid Unt:*

26.02.2025.

Pečat i Potpis ovlašćenog lica:  
*Seal and Sign:*

Dipl. inž. šum. Ilija Smiljanić



# TEHNOELEKTRO-TIM D.O.O.

Lele Popović b.b., 18220 Aleksinac, Srbija  
Tel/Fax +381 18 800-252, 800-253, 800-392, 800-393.

[info@tehoelektro.rs](mailto:info@tehoelektro.rs) [www.tehoelektro.rs](http://www.tehoelektro.rs)


RB/MB:20906227; PD:2790; PIB:107964407

Komercijalna banka: 205-187000-39; Čačanska banka: 155-23572-07

## DEKLARACIJA USAGLAŠENOSTI

O

**No.003/20**

<b>Adresa proizvođača</b>	TEHNOELEKTRO TIM Lele Popovic bb, 18220 Aleksinac, Srbija
<b>Proizvod</b>	<b>Priključnica sa USB punjacom</b>
<b>Robna marka proizvoda</b>	
<b>Br. artikla / Tip</b>	2/310-0113/ UP+2, 2/310-0114/PP5/2+2, 2/310-0115/PP5/3+2, 2/310-0116 PP5/5+2
<b>Osnovne karakteristike proizvoda</b>	Napon / struja priključnice 250V/16A Napon na izlazu punjaca 5V Struja punjaca 2A
<b>Propisi / Standardi</b>	SRPS IEC 60884-1 SRPS IEC 60884-2-7 SRPS IEC 60950-1 Ispitni izveštaj TMP 03
<b>Napomena</b>	Pravilnik o električnoj opremi namenjenoj za upotrebu u okviru određenih granica napona Sl Glasnik R.S. br 25/2016. Deklaracija je izdata na osnovu potvrde o usaglasenosti br P2-084/20 od strane sretifikacionog tela Jugoinspekt AD Beograd

Aleksinac, 26.02. 2020.

*Bojan Milutinović*

Bojan Milutinovic, M.Sc.E.  
IT & QMS manager  
Sluzba kontrole kvaliteta



IQM 20